Ontario Ministry of the Environment

WATER WELL RECORD

Print only in spaces provided.
Mark correct box with a checkmark, where applicable.

County or District	Township/Borough/City/Town/Village	Con. block tract survey, etc.	Lot
PARRY SOUND	McMURRICH	M375	1

Owner's surname	First Name	Address	Date completed (day / month / year)
STEELE	BOB	199 ALMAGUIN DR, SPRUCDALE.	26 05 03

Zone | Easting | Northing

LOG OF OVERBURDEN AND BEDROCK MATERIALS (see instructions)

General colour	Most common material	Other materials	General description	Depth - feet From	Depth - feet To
BROWN	SAND			0	16
GREY	ROCK.			16	205

WATER RECORD

Water found at - feet	Kind of water
89	X Fresh / Salty / Sulphur / Minerals / Gas
200	X Fresh / Salty / Sulphur / Minerals / Gas
	Fresh / Salty / Sulphur / Minerals / Gas
	Fresh / Salty / Sulphur / Minerals / Gas
	Fresh / Salty / Sulphur / Minerals / Gas

CASING & OPEN HOLE RECORD

Inside diam inches	Material	Wall thickness inches	Depth - feet From	Depth - feet To
6 1/4	X Steel / Galvanized / Concrete / Open hole / Plastic	.188	+1.5	20
6	Steel / Galvanized / Concrete / X Open hole / Plastic		20	205
	Steel / Galvanized / Concrete / Open hole / Plastic			

SCREEN

Sizes of opening (Slot No.)	Diameter inches	Length feet
Material and type	Depth at top of screen feet	

PLUGGING & SEALING RECORD

X Annular space / Abandonment

Depth set at - feet From	Depth set at - feet To	Material and type (Cement grout, bentonite, etc.)
		BENTONITE

PUMPING TEST

Pumping test method: X Pump / Bailer
Pumping rate: 3 GPM
Duration of pumping: 1 Hours 10 Mins

Static level	Water level end of pumping	Water levels during X Pumping / Recovery: 15 minutes	30 minutes	45 minutes	60 minutes
40 feet	175 feet	175 feet	175 feet	175 feet	175 feet

If flowing give rate: GPM
Pump intake set at: 175 feet
Water at end of test: Clear / X Cloudy
Recommended pump type: Shallow / X Deep
Recommended pump setting: 175 feet
Recommended pump rate: 3 GPM

LOCATION OF WELL

In diagram below show distances of well from road and lot line. Indicate north by arrow.



253786

FINAL STATUS OF WELL

X Water supply / Observation well / Test hole / Recharge well / Abandoned, insufficient supply / Abandoned, poor quality / Abandoned (Other) / Dewatering / Unfinished / Replacement well

WATER USE

X Domestic / Stock / Irrigation / Industrial / Commercial / Municipal / Public supply / Cooling & air conditioning / Not use / Other

METHOD OF CONSTRUCTION

Cable tool / Rotary (conventional) / Rotary (reverse) / X Rotary (air) / Air percussion / Boring / Diamond / Jetting / Driving / Digging / Other

Name of Well Contractor	Well Contractor's Licence No.
MARSHALL WELL DRILLING	3678

Address: HWY 11 EMSDALE ONT.

Name of Well Technician	Well Technician's Licence No.
ROB MARSHALL	T-1638

Signature of Technician/Contractor: J. Marshall
Submission date: 25 06 03 (day mo yr)

MINISTRY USE ONLY

1 - CONTRACTOR'S COPY

0506 (07/00) Front Form 9