



Ministry
of the
Environment
Ontario

USE PERMIT
FOR CLASS 4, 5, 6 SEWAGE SYSTEMS

APPLICATION NO.
CH/33/79

INSPECTION DETAILS	TIME	DATE	WEATHER
	2: P.M.	Aug 6/79	CLEAR
REPRESENTING:	THE OWNER	THE INSTALLER	
	N/A	N/A	

1. Work authorized by the Certificate of Approval has been satisfactorily completed and includes:

- a) Septic tank/holding tank of working capacity of 800 Imp. Gals. constructed of steel ☐ concrete ☒ fibreglass ☐ on site ☐ or prefabricated ☒ to serve 3 (no. of bedrooms or units).

MAKE AND MODEL,

IF PREFABRICATED TANK

BROOKLIN CONCRETE

- b) Leaching bed of total 200 lineal feet of 4 inch diameter distribution pipe of P.V.C (type and product description e.g. Canron CSA Approved PVC) laid in 4 runs and fed by GRAVITY (gravity, siphon, pump).
- c) Proprietary Aerobic System: (Manufacturer) _____ (Model) _____
- d) Other details _____

2. Location

- a) System components installed as shown on application supporting Certificate of Approval ☒
- b) If located other than in (a) use space below for sketch and dimensions from permanent points of reference sufficient to facilitate future location of tank and leaching bed including orientation of pipe runs.



3. The following work remains to be completed:—

- ☒ Backfill System and Complete ☐ Finish Grading to Shed Run-off and Divert Water Around Leaching Bed
- ☐ Stabilize All Sloped Surfaces ☐ Other

USE PERMIT

Under Section 59a of The Environmental Protection Act, 1971 and subject to the provisions of The Act and Regulations a Permit is hereby issued to (Owner) ROBERT & REBECCA MAXWELL for the use and operation of the Class IV sewage system constructed/installed/enlarged/extended/alterd pursuant to the Certificate of Approval issued under the above application number in accordance with the application and Certificate of Approval with any changes indicated above and located on Lot 15 Concession 8 Ward/Township/Municipality Chaffey Region/District/County Muskoka Plan No. -- Sub-Lot No. --

INSPECTED AND RECOMMENDED BY

P. Savoie

PERMIT ISSUED BY

David N. Kerr

DIRECTOR

DATE ISSUED

September 10/79

Note: Section 57(a) of The Act provides that no change can be made to any building(s) or structure(s) in connection with which this sewage system is used, if the operation or effectiveness of the sewage system will or is likely to be affected by the change, unless a new Certificate of Approval is obtained.

Section 78 of The Act provides that an applicant for a permit may appeal a decision to refuse to issue a permit. Written notice of appeal must be forwarded to the Director (who refused to issue the permit) and to the Environmental Appeal Board, 1 St. Clair Avenue West, Toronto, Ontario, M4V 1K7 within 15 days of receipt of a permit.

APPLICATION FORM AND CERTIFICATE OF APPROVAL FOR A CLASS 2-6 SEWAGE SYSTEM

(Please Print Clearly)

Application No. CH/33/79Fee Receipt No. 64744Date Received Aug. 21. 79

1. Name of Owner <u>Robert + Rebecca Maxwell</u>		Tel. No. <u>789-2019</u>		2. Installer's Name		Tel. No.	
Address <u>RR #3 Box 56 Old North Rd.</u> (No., Street, City, Town, etc.) <u>Huntsville Ontario</u>				Address (No., Street, City, Town, etc.)			
3. Propose to <u>CONSTRUCT</u> a Class <u>4</u> sewage system to serve <u>SINGLE FAMILY</u> (Construct/Install/Alter/Extend/Enlarge) (Facility: e.g. Single Family Dwelling, Motel, etc.)							
4. Location - Region, County, District <u>LT5-68 Chaffee Twp. Muskoka</u>		Ward, Township, Town <u>Chaffee Township Huntsville</u>		Lot No. <u>15</u>	Conc. No. <u>8</u>	Sub.Lot. No.	Plan No.
5. State No. of	Bedrooms or Motel Units <u>3</u>	People <u>4</u>	Flush Toilets <u>1</u>	Urinals	Washbasins <u>1</u>	Showers and Bathtubs <u>1</u>	6. Water Supply
							Dug or Bored Well ☒ Drilled Well ☐ Municipal ☐ Other Proposed ☐ or Existing ☐

7. Attach completed sketch on Page 2 - List other attachments:

8. Relationship to Severance if applicable ☐ Lot Approval Pending ☐ Lot Approved Under Severance Application No.	9. Directions to Lot: - Highway No., Secondary Roads, Signs to Follow, etc. <u>MELISSA - UP PASSED EDS RIDING STABLE BARN ...</u> <u>GRAVEL ROAD, UP ON TOP OF THE HILL ...</u> <u>DIRECTLY ACROSS FROM A DOUBLE MOBILE HOME</u> <u>ON THE RIGHT HAND SIDE OF THE ROAD.</u>
--	---

10. I certify that the above information is complete and correct and that, if approved, the work will conform with Provincial requirements for sewage systems and local Municipal By-Laws. (Attach fee for Class 4, 5 or 6 systems)

Name of Agent	Tel. No.	Signature of Owner or Agent <u>Robert Maxwell</u>
Address (No., Street, City, Town, etc.)		Date <u>Aug. 20. 1979</u>

11. INSPECTOR'S REPORT		Inspection Time and Date <u>2:45 PM Aug. 23. 19. 79.</u>	Sub-Surface Conditions Encountered	
Weather <u>OVERCAST</u>	Representing Owner <u>N/A</u>	Leaching Bed Design Criteria		Rock & G.W.T. Elevation Soil Type <u>SAND</u>
REQUIREMENTS	Lineal Feet of Distribution Pipe <u>200</u>	Depth to Rock Ft.	Design H.W.T. Ft.	
		Working Capacity of Septic/Holding Tank Imp. Gallons <u>800</u>		

Conditions of Approval and Reasons (e.g. fill, grading, drainage improvements, design sewage flows). ☒
ORReasons where Proposal not Acceptable (add additional pages if required) ☐


The septic tank system is to be installed a minimum of 100 feet from the dug well.

The septic tank system is to be installed to meet this Ministry's requirements.



12. LOT DIAGRAM AND SEWAGE SYSTEM PLAN: — Draw to scale indicating north point and showing:

- Location of sewage system components (e.g. tanks, leaching bed). Locate and show horizontal distances from system to adjacent existing or proposed buildings, water supplies (including neighbours), existing on-site sewage systems, driveways, property lines, lakes, rivers, water courses, swimming pools.
- Lot dimensions, topographic features (e.g. swamps, steep slopes) near system.
- If any part of proposal conforms to a specific standard drawing, give reference number(s).



13. A Certificate of Approval for this application is refused for the reasons given in Section 11 Page 1

INSPECTED AND RECOMMENDED BY

REFUSED

DATE

DIRECTOR

CERTIFICATE OF APPROVAL

Application approved and this Certificate of Approval under Section 57 of The Environmental Protection Act, 1971 is hereby issued for the proposal outlined on Pages 1 and 2 of the application and its attachments as amended by the requirements and conditions of Section 11 provided that the sewage system shall be completed and a Use Permit issued within 12 months of the issue hereof or such extended period as the Director on application allows. DO NOT OPERATE THE SYSTEM UNTIL A USE PERMIT IS ISSUED.

INSPECTED AND RECOMMENDED BY

ISSUED

DATE

P. Savoie

David N. Kerr

DIRECTOR

August 23, 1979

Under Section 78 of The Environmental Protection Act, 1971, an applicant may appeal a decision by writing to the Director and to the Environmental Appeal Board, 1 St. Clair Avenue West, Toronto, Ont., M4V 1K7 within 15 days of receipt of the decision.